

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Sunset-on-Seneca Campground (ID: 308168 )  
Facility Name: sunset-on-seneca campsites  
Facility Code: 49-0488  
Facility Address: 8449 LOWER LAKE ROAD

To the Attention of:

### Sanitary Survey

Date: JUL 22, 2015 09:17 AM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: to be mailed (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:05, from bathroom cwt; Chlorine residual - 1.66 mg/l, collection time 2:00 from Bathroom cwt;

### Comments

7/21/2015 @ 2pm- property has two wells. one feeds the house and other sites. the second provides sites and bathrooms. at bathroom a sample was taken and free cl reading showed 1.66. both are disinfection types are uv systems with no chlorination added. the system was flushed and another reading taken, chlorine was found in the system again. after speaking to supervisor the sample was accepted and will be sent to the lab for analysis.

END of REPORT

[Submit# 142139] Sunset-on-Seneca Campground (ID 308168) Inspection# 1001680968