

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: WATERLOO SPORTSMAN CLUB WATER (ID: 308505)
Facility Name: waterloo sportsman club
Facility Code: 49AD12
Facility Address: 2654 EDWARDS ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: JUL 07, 2015 08:40 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Dorris Ross (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 9:25am, from Kitchen CWT; Chlorine residual - 0 mg/l, collection time 9:30am from Kitchen CWT;

Comments

Total Coliform water sample taken kitchen CWT. Nitrate water sample taken entry point. UV system is functioning properly. Extra Bulb and sleeve on site. Well was evaluated and found to be in good condition.

END of REPORT

[Submit# 139343] WATERLOO SPORTSMAN CLUB WATER (ID 308505) Inspection# 1001675019