

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Swimming Pool Inspection - Summary Report

Operation: Junius Ponds -outdoor pool (ID: 308155)
Facility Name: JUNIUS PONDS CABINS/CAMPGROUND LLC
Facility Code: 49-AJ82
Facility Address: 1475 WEST TOWNLINE ROAD PHELPS, NY 14532

To the Attention of:
ERIC DADSON
1475 WEST TOWNLINE ROAD
PHELPS , NY 14532-

Inspection
Date: JUL 29, 2015 04:33 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: to be mailed (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 2

Each item found in violation is reported below along with the code requirement.

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 23 WAS FOUND IN VIOLATION 1 TIME(s).
All or parts of the violation item are IN violation.

Code Requirements

Lifesaving Equipment Adequate/Accessible, Lifeguard Chairs {6-1.23(b)}

Inspector Findings

Two U.S. Coast Guard approved ring buoys with line are required for level 4 pools, currently one is available. Additional required items include: First aid kit Pocket mask or face shield

RECORDS/SIGNS

ITEM # 18 WAS FOUND IN VIOLATION 1 TIME(s).
All or parts of the violation item are IN violation.

Code Requirements

Pool Safety Plan Developed/Implemented/Updated {6-1.23(c)}

Inspector Findings

Safety Plan not on file with Health department and updated

Additional Information Collected During Inspection

Flow meter reading (gpm) - 140; Free chlorine/bromine - 1.4 mg/L; Combined chlorine - 3.0 mg/L; PH - 7.6; Total alkalinity - 170 mg/L;
Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

Saturation index at 0.3

END of REPORT

[Submit# 144901] Junius Ponds -outdoor pool (ID 308155) Inspection# 1001686767