

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Lameroux Landing (ID: 308848 )  
Facility Name: lameroux landing  
Facility Code: ag-06  
Facility Address: Rt. 414

### To the Attention of:

Mark Wagner  
9224 Rt. 414  
Iodi , ny 14860-

### Sanitary Survey

Date: AUG 05, 2015 03:02 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Brenda Clawson (email: brendac@lamoreauxwine.com )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:11pm, from Kitchen cwt; Chlorine residual - 0 mg/l, collection time 3:00 from Kitchen cwt;

### Comments

Total Coliform water sample taken kitchen cwt. Nitrate water sample taken kitchen cwt. Disinfection Waiver is issued to this facility. No disinfection system in place. If positive water samples are received from lamoreaux, the disinfection waiver will be reviewed to determine if it is necessary to install a disinfection system.

END of REPORT

[Submit# 144881] Lameroux Landing (ID 308848) Inspection# 1001686737