

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: STANDING STONE VINEYARDS (ID: 857809)
Facility Name: standing stone vineyards
Facility Code: 49-6312
Facility Address: 9934 ROUTE 414 HECTOR, NY 14841

To the Attention of:

Sanitary Survey

Date: AUG 19, 2015 02:33 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Tom Macinski (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARD

VIOLATION OF 5-1.30(a) WAS OBSERVED. (# 7)

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

5-1.30(a)(b) [ND] Disinfection of a groundwater source. CI and UV equipment is operating as designed. If UV is working, indicator light is On, intensity meter is >70%.

Inspector Findings

Public Health Hazard - UV Light was un-plugged during at time of inspection. Corrected plugged in. UV light was functioning properly.

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:33pm, from tasting room cwt; Chlorine residual - 0 mg/l, collection time 2:30pm from tasting room cwt;

Comments

Total Coliform water sample taken tasting room CWT. Nitrate water sample taken tasting room CWT. Well was evaluated and found in good conditon. Inspector found the ultra-violet disinfection system un-plugged during the time of inspection. If light is found un-plugged in future inspections violations and possible enforcement actions will be possible.

END of REPORT

[Submit# 147356] STANDING STONE VINEYARDS (ID 857809) Inspection# 1001693067