

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Village soft serve (ID: 308890)
Facility Name: village soft serve no. 1
Facility Code: 49-AB16
Facility Address: 5141 ROUTE 414 LODI, NY 14860

To the Attention of:

Sanitary Survey

Date: AUG 04, 2015 03:18 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Mariah Chase-Wegner (email: dcwurma@fltg.net)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:14pm, from kitchen cwt; Chlorine residual - 0 mg/l, collection time 3:00pm from kitchen cwt;

Comments

Total coliform water sample taken kitchen cwt. Yearly nitrate water sample taken cwt. Operation reports and dddwater samples must be submitted monthly to maintain a disinfection waiver.

END of REPORT

[Submit# 144642] Village soft serve (ID 308890) Inspection# 1001686195