

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Welcome Traveler (ID: 308427)
Facility Name: welcome traveler campground
Facility Code: 49-0514
Facility Address: 672 PACKWOOD ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: AUG 18, 2015 02:10 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Margret Ann Williams (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:03pm, from Bathroom cwt; Chlorine residual - 0 mg/l, collection time 2:00pm from Bathroom cwt;

Comments

Total coliform water sample taken bathroom CWT. Nitrate water sample taken bathroom CWT. UV Light and well was inspected. Facilities were found in good condition,

END of REPORT

[Submit# 147066] Welcome Traveler (ID 308427) Inspection# 1001692616