

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Public Water Supply Inspection - Summary Report

Operation: Sheldrake Point Winery WATER (ID: 308221 )  
Facility Name: sheldrake point vineyard llc  
Facility Code: 49-AB97  
Facility Address: 7448 COUNTY ROAD 153 OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: SEP 14, 2015 01:26 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Bruce Vann (email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - Yes; Coliform surveillance sample collected - Yes, collection time 1:30pm, from Utility bathroom; Chlorine residual - .99 mg/l, collection time 1:35pm from Utility Bathroom;

Comments

Total Coliform water sample taken, Nitrate water sample taken. Extra bulb and sleeve on-site. Well was evaluated and found in good condition

END of REPORT

[Submit# 151430] Sheldrake Point Winery WATER (ID 308221) Inspection# 1001749036