

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Lodi Point State Park (ID: 308904)
Facility Name: lodi point state park
Facility Code: 4911818
Facility Address: Lower Lake Road

To the Attention of:

Sanitary Survey

Date: SEP 30, 2015 10:45 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Stephen Garlick (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 10:45am, from Mens Lav; Chlorine residual - 1.24 mg/l, collection time 10:47am from Utility Room;

Comments

Total Coliform water sample taken Mens Lav CWT. Nitrate water sample taken entry point. Well was evaluated and found in good condition.

END of REPORT

[Submit# 152552] Lodi Point State Park (ID 308904) Inspection# 1001752160