

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Fayette Mennonite School (ID: 308113)
Facility Name: Fayette Mennonite School
Facility Code: 49-AC00
Facility Address: 1408 Leader ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: MAR 28, 2016 03:58 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Nathan Hoover
(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:47pm, from Basement Sink; Chlorine residual - 0 mg/l, collection time 4:00pm from Basement Sink;

Comments

Nitrate water sample taken.
TC water sample taken.

END of REPORT

[Submit# 186353] Fayette Mennonite School (ID 308113) Inspection# 1001809548