

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Bellwether Hard Cider (ID: 499314)
Facility Name: Bellwether Hard Cider
Facility Code: 4930300
Facility Address: 9070 Rt. 89 ROUTE Trumansburg, NY 14886

To the Attention of:
William Barton
63 woodcrest Ave.
Ithaca , NY 14850-

Sanitary Survey

Date: APR 26, 2016 01:37 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: William Barton
(email: bill@cidery.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:43pm, from Utility room CWT; Chlorine residual - 0 mg/l, collection time 2:\35pm from Utility Room;

Comments

Total Coliform water sample taken Utility Room CWT.
Nitrate water sample taken Utility Room CWT.
UV light was inspected and found in good condition.
Well was evaluated and found in good condition.

END of REPORT