

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Glenwood Foods (ID: 449861 )  
Facility Name: Glenwood Foods  
Facility Code: ag-55  
Facility Address: State Route 318

To the Attention of:  
Carl Martin  
2961 Rt. 318  
Seneca Falls , NY 13148-

Sanitary Survey  
Date: APR 05, 2016 12:17 PM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: Mary Sue Martin  
(email: )

Summary  
Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

### PUBLIC HEALTH HAZARD

#### **VIOLATION OF 5-1.23(b) WAS OBSERVED. (# 3)**

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

##### Code Requirements

5-1.23(b) [SE] Notify State when delivery of water is interrupted  
for a period of four hours or more.

##### Inspector Findings

Public Health Hazard -

##### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance  
sample collected - Yes, collection time 12:22 pm, from prep sink;

##### Comments

water had foul smell during visit. water softener will be looked at.

END of REPORT

[Submit# 188181] Glenwood Foods (ID 449861) Inspection# 1001811841