

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Waterloo Mennonite School (ID: 308110)
Facility Name: Waterloo Mennonite School
Facility Code: 49-AC02
Facility Address: 3028 Miller ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: APR 04, 2016 10:30 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Janice Auker
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 10:29am, from Men's Lav CWT; Chlorine residual - 0 mg/l, collection time 9:45am from utility Room CWT;

Comments

UV light was inspected and found in good condition.
Well was evaluated and found in good condition.
Total Coliform water sample taken Men's Lav CWT.
Nitrate water sample taken EP.

END of REPORT