

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: NORTH SENECA SPORTSMAN CLUB WATER (ID: 878263)

Facility Name: NORTH SENECA SPORTSMAN CLUB

Facility Code: 49-2411

Facility Address: 334 ROUTE 318 PHELPS, NY 14532

To the Attention of:

Sanitary Survey

Date: MAY 04, 2016 04:28 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Jim Schaup

(email: northsenecasc@gmail.com)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 4:21pm, from Lav CWT; Chlorine residual - .51 mg/l, collection time 4:18 from Kitchen;

Comments

Total Coliform water sample taken.

Nitrate water sample taken.

Water is delivered to the sportsman club by Willy's Water.

Completed works inspection completed on new ultra violated system.

Reviewed water sampling and operation requirements.

North Seneca will be required to sample on a quarterly basis.

Monthly operation reports are required.

END of REPORT

[Submit# 195435] NORTH SENECA SPORTSMAN CLUB WATER (ID 878263) Inspection# 1001821744