

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: THIRSTY OWL WINE COMPANY, INC. ONSITE WATER SUPPLY (ID: 506519)
Facility Name: THIRSTY OWL WINE COMPANY, INC.
Facility Code: 49-05805
Facility Address: 6799 ELM BEACH ROAD OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: MAY 09, 2016 10:10 AM

Inspector: Melissa Brand (mbrand@co.seneca.ny.us)

Responsible Person: Jon Cupp

(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 10:58, from tasting room cwt;

Comments

discussed second water softener as potential to be added.

END of REPORT

[Submit# 196218] THIRSTY OWL WINE COMPANY, INC. ONSITE WATER SUPPLY (ID 506519) Inspection# 1001823361