

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Americana Winery (ID: 308843 )  
Facility Name: Americana Winery  
Facility Code: AG-01  
Facility Address: East Covert Rd

To the Attention of:

### Sanitary Survey

Date: JUL 13, 2016 02:32 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Dan Zannella  
(email: )

### Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:35pm, from Kitchen CWT; Chlorine residual - 0.46 mg/l, collection time 2:25pm from Kitchen CWT;

### Comments

Total Coliform water sample taken kitchen CWT.  
Nitrate water sample taken kitchen CWT.  
Well and chlorine unit inspected and found in good condition.

END of REPORT

[Submit# 212980] Americana Winery (ID 308843) Inspection# 1001844891