

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: BOATHOUSE BEER GARDEN WATER (ID: 889355)
Facility Name: BOATHOUSE BEER GARDEN
Facility Code: 49-0064
Facility Address: 6128 ROUTE 89 ROMULUS, NY 14541

To the Attention of:

Sanitary Survey

Date: JUL 12, 2016 12:31 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Peter Arena
(email: parena@gmail.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - Yes; Coliform surveillance sample collected - Yes, collection time 2:10pm, from Utility room CWT; Chlorine residual - .26 mg/l, collection time 2:05pm from Utility room CWT;

Comments

Total Coliform water sample taken.
Nitrate water sample taken.
Well and UV disinfection system inspected and found in good condition.

END of REPORT

[Submit# 212448] BOATHOUSE BEER GARDEN WATER (ID 889355) Inspection# 1001844335