

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: BUSY BEE MARKET AND CAFE WATER (ID: 308209)
Facility Name: BUSY BEE MARKET AND CAFE AT KIDDER'S
Facility Code: 49-AA47
Facility Address: 7930 COUNTY ROAD 153 INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: JUN 29, 2016 02:10 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Jennifer McLafferty
(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:16pm, from Kitchen CWT; Chlorine residual - 0 mg/l, collection time 2:00pm from Kitchen CWT;

Comments

Total Coliform water sample taken.

Nitrate water sample taken.

UV light and well was found to be in good condition.

END of REPORT