

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Mobile Home Park Inspection -- Summary Report

Operation: COUNTRY MEADOWS COURT (ID: 308092)
Facility Name: COUNTRY MEADOWS COURT
Facility Code: 49-1237
Facility Address: 2815 MILLER ROAD WATERLOO, NY 13165

To the Attention of:
EDWARD K BROWN
1661 LEADER ROAD
WATERLOO , NY 13165-

Inspection

Date: JUL 21, 2016 09:32 AM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Ed Brown
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FIRE SAFETY

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Mobile Homes meet applicable construction standards {17.5(a)(2), (3)}

Inspector Findings

some of the mobile homes according to interviews with tenants and owner have issues due to the age of the mobile homes i.e. plumbing corroded reduces water pressure; vents in heating system not working completely; appliances tripping breakers if line is overloaded

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 216636] COUNTRY MEADOWS COURT (ID 308092) Inspection# 1001849394