

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: TORO RUN WATER SUPPLY (ID: 872980)
Facility Name: J & C DEVELOPERS
Facility Code: 49-3541
Facility Address: 3050 SWICK ROAD OVID, NY 14521

To the Attention of:

Field Visit

Date: JUL 13, 2016 12:38 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: TO BE MAILED
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARD

VIOLATION OF 5-1.30(g) WAS OBSERVED. (# 10)

All or parts of the violation item are IN violation.

Code Requirements

5-1.30(g) [NR] Maintain free chlorine residual at representative points
in the distribution system.

Inspector Findings

Public Health Hazard - Residual not available. Will flush 120 gal tank and increase ratio of chlorine to water in solution tank. Should be using 16 oz of chlorine for every 20 gallons of water in the solution on tank.

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - No ;

Comments

END of REPORT

[Submit# 213063] TORO RUN WATER SUPPLY (ID 872980) Inspection# 1001844980