

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: TORO RUN WATER SUPPLY (ID: 872980 )  
Facility Name: J & C DEVELOPERS  
Facility Code: 49-3541  
Facility Address: 3050 SWICK ROAD OVID, NY 14521

To the Attention of:

### Field Visit

Date: JUL 22, 2016 02:03 PM  
Inspector: Melissa Brown (mbrand@co.seneca.ny.us)  
Responsible Person: Justin Coppola  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

### Comments

Facility purchased digital DPD kit. reading on kit at 2.5. Inspectors kit read 1.69. Will be looking into the calibration of inspection kit for accuracy. Facility had 2.5 chlorine level at brining of day and again during field visit.

---

END of REPORT

[Submit# 217833] TORO RUN WATER SUPPLY (ID 872980) Inspection# 1001850745