

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: Babcock Hovey - Outdoor Pool (ID: 308214)
Facility Name: BABCOCK-HOVEY BSA
Facility Code: 49-0019
Facility Address: 7294 COUNTY ROAD 132 ROAD OVID, NY 14521

To the Attention of:
STEVE HOITT SENECA WATERWAYS COUNCIL, BSA
2320 BRIGHTON HENRIETTA TOWNLINE RD
ROCHESTER , NY 14623-

Inspection

Date: JUL 18, 2016 02:08 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Jay Laitenberger
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 24 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Pool Fenced, Self-Closing/Self Latching Gates or Doors {6-1.16}

Inspector Findings

gate is not self closing if opened; a lifeguard is stationed at gate to ensure proper closure and buddy tag use

Additional Information Collected During Inspection

Pool/Spa water temperature - 78 degrees Fahrenheit; Free chlorine/bromine - 2 mg/L; PH - 7.1; Total alkalinity - 80 mg/L; Supervision level - IIb; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 224214] Babcock Hovey - Outdoor Pool (ID 308214) Inspection# 1001859459