

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: CAMP BABCOCK-HOVEY CUB SCOUTS OUTDOOR POOL (ID: 809916)
Facility Name: CAMP BABCOCK-HOVEY CUB SCOUTS
Facility Code: 49-1322
Facility Address: 7294 COUNTY ROAD 132 OVID, NY 14521

To the Attention of:

Re-Inspection

Date: AUG 22, 2016 04:01 PM

Inspector: Julie Hoster (jhoster@co.seneca.ny.us)

Responsible Person: Kevin Cowles

(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected: 0

Number of other violations found: 2

Each item found in violation is reported below along with the code requirement.

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 24 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Pool Fenced, Self-Closing/Self Latching Gates or Doors {6-1.16}}

Inspector Findings

gate by filter room and office was not attached correctly; making it easily maneuverable and allowing for easy access

SUPERVISION/STAFF

ITEM # 57 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Records - Certifications/Qualifications, Level IV Log, TR/Campground Supervision Declaration {6-1.23(a)(1)(i), 6-1.23(a)(9), 6-1.23(a)(10)(ii)}

Inspector Findings

Unable to locate certification for 1 lifeguard; enough qualified lifeguards on staff for pool operation; will forward lifeguards certification to SCDOH

Additional Information Collected During Inspection

Free chlorine/bromine - 4.0 mg/L; PH - 7.0; Total alkalinity - 60 mg/L; Calcium hardness - 320 mg/L; Supervision level - IIb; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 229181] CAMP BABCOCK-HOVEY CUB SCOUTS OUTDOOR POOL (ID 809916) Inspection# 1001866209