

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Driftwood Inn (ID: 308198)
Facility Name: DRIFTWOOD INN
Facility Code: 49-0627
Facility Address: 7401 WYERS POINT ROAD OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: AUG 17, 2016 10:12 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Jim Steuer
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - Yes; Coliform surveillance sample collected - Yes, collection time 10:05am, from Kitchen CWT; Chlorine residual - 0.24 mg/l, collection time 10:00am from Kitchen CWT;

Comments

Total Coliform and Nitrate sample taken.
Well and UV disinfection system inspected and found in good condition.

END of REPORT

[Submit# 227955] Driftwood Inn (ID 308198) Inspection# 1001864855