

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: Holiday Inn Outdoor Pool (ID: 308305)
Facility Name: HOLIDAY INN
Facility Code: 49-1365
Facility Address: 2468 414 ROUTE WATERLOO, NY 13165

To the Attention of:
SERVUS HOTEL GROUP WATERLOO LLC
6731 Professional Pkwy W. Suite 100
SARASOTA , FL 34240-8491

Inspection

Date: AUG 11, 2016 11:48 AM
Inspector: Melissa Brown (mbrand@co.seneca.ny.us)
Responsible Person: Bobby Jo Halstead
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FILTER ROOM & EQUIPMENT

ITEM # 49 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Chemicals Approved, Proper Storage/Handling/Labeling {6-1.11(c)(1)-(4), (d)}

Inspector Findings

chlorine tank did not have a catch basin underneath. this prevents the chlorine from potentially spilling onto the floor should the vessel have a puncture.

Additional Information Collected During Inspection

Pool/Spa water temperature - 81 degrees Fahrenheit; Flow meter reading (gpm) - 275; Free chlorine/bromine - 2.0 mg/L; PH - 7.0; Total alkalinity - 280 mg/L; Calcium hardness - 30 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 225214] Holiday Inn Outdoor Pool (ID 308305) Inspection# 1001860684