

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Kingtown Beach and Cottages (ID: 308064)
Facility Name: KINGTOWN BEACH COTTAGES & CAMP
Facility Code: 49-0678
Facility Address: 9305 KINGTOWN BEACH ROAD TRUMANSBURG, NY 14886

To the Attention of:

Sanitary Survey

Date: AUG 01, 2016 02:34 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Gregory Szabo
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:35pm, from Cabin 1 CWT; Chlorine residual - 0.87 mg/l, collection time 2:40pm from Cabin 1 CWT;

Comments

UV disinfection system was found in good working order.

END of REPORT

[Submit# 220806] Kingtown Beach and Cottages (ID 308064) Inspection# 1001854184