

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Swimming Pool Inspection -- Summary Report

Operation: Oak Orchard Campground Outdoor Pool (ID: 517050 )  
Facility Name: OAK ORCHARD CAMPGROUNDS  
Facility Code: 49-0096  
Facility Address: ROUTE 89 AT MAYS POINT SAVANNAH, NY 13146

To the Attention of:  
RICHARD T KRAMER  
PO BOX 148  
SENECA FALLS , NY 13148-

### Inspection

Date: AUG 04, 2016 12:52 PM  
Inspector: Melissa Brown (mbrand@co.seneca.ny.us)  
Responsible Person: Richard Kramer  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Pool/Spa water temperature - 82 degrees Fahrenheit; Free chlorine/bromine - 1.0 mg/L; PH - 7.4; Total alkalinity - 90 mg/L; Calcium hardness - 610 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

### Comments

---

END of REPORT

[Submit# 223407] Oak Orchard Campground Outdoor Pool (ID 517050) Inspection# 1001858060