

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Silverthread Winery water (ID: 851559 )  
Facility Name: Silverthread Winery  
Facility Code: 49-ag60  
Facility Address: 1401 Caywood ROAD Lodi, NY 14860

To the Attention of:

### Sanitary Survey

Date: JUL 27, 2016 02:30 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Shannon Brock  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:31pmk, from tasting room sink; Chlorine residual - 0 mg/l, collection time 2:36pm from tasting room cwt;

### Comments

Total Coliform water sample taken.  
Nitrate water sample taken.  
UV light was inspected and found in good condition,

END of REPORT