

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: TORO RUN WATER SUPPLY (ID: 872980 )  
Facility Name: J & C DEVELOPERS  
Facility Code: 49-3541  
Facility Address: 3050 SWICK ROAD OVID, NY 14521

To the Attention of:

### Sanitary Survey

Date: JUL 26, 2016 02:31 PM  
Inspector: Melissa Brown (mbrand@co.seneca.ny.us)  
Responsible Person: Chris Weaver  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:29, from Bathroom Cold Water Tap; Chlorine residual - 5.61 mg/l, collection time 2:25 from Bathroom CWT;

### Comments

Previous visits indicated the CI level to be below required residual. After visits it was determined that the inspectors chemical equipment was outdated. Equipment at facility will only test to 2.5, current inspector reading is 5.61. Water will be added to crock to dilute the concentration and will bring the residual down to more acceptable numbers. Please advise patrons against drinking the water until the chlorine level can be brought down to 2.0.

END of REPORT