

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: ROCHESTER SYRACUSE AUTO AUCTION WATER (ID: 308327)
Facility Name: ROCHESTER/SYRACUSE AUTO AUCTION.
Facility Code: 49-AA86
Facility Address: 1826 ROUTE 414 WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: SEP 13, 2016 03:05 PM

Inspector: Thomas Scoles (tscoles@co.seneca.ny.us)

Responsible Person: Scott Prankie
(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PART 5 REQUIREMENTS

VIOLATION OF App.5-B.5(g) WAS OBSERVED. (# 32)

All or parts of the violation item are IN violation.

Code Requirements

App.5-B.5(g) [SO] Well cap makes proper sanitary seal, is vented, watertight, and vermin proof.

Inspector Findings

Significant Deficiency - well cap off of well , must be replaced as soon as possible

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:15 pm, from kcwt;

Comments

total coliform sample collected,nitrate water sample collected

END of REPORT

[Submit# 234537] ROCHESTER SYRACUSE AUTO AUCTION WATER (ID 308327) Inspection# 1001873485