

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Public Water Supply Inspection -- Summary Report

Operation: Sheldrake Point Winery WATER (ID: 308221)

Facility Name: SHELDRAKE POINT VINEYARD LLC

Facility Email: FINEWINE@SHELDRAKEPOINT.COM

Facility Code: 49-AB97

Facility Address: 7448 COUNTY ROAD 153 OVID, NY 14521

To the Attention of:

Owner/Operator Email: None

Sanitary Survey

Date: NOV 09, 2016 02:06 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Ronata Stapel

(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected: 0

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Ground water under the direct influence of surface water; 4-Log Treatment installed - Yes; Coliform surveillance sample collected - Yes, collection time 2:07pm, from Tasting Room CWT; Chlorine residual - 0.6 mg/l, collection time 2:10pm from tasting cwt;

Comments

Total Coliform water sample taken.

Nitrate water sample taken.

END of REPORT

[Submit# 248260] Sheldrake Point Winery WATER (ID 308221) Inspection#

1001889782