

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Public Water Supply Inspection -- Summary Report

Operation: Zugibe Winery (ID: 796649)  
Facility Name: ZUGIBE VINEYARDS Facility Email: None  
Facility Code: 49-6042  
Facility Address: 4248 EAST LAKE ROAD GENEVA, NY 14456

To the Attention of:

Owner/Operator Email: None

Sanitary Survey

Date: NOV 01, 2016 11:20 AM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: crystal moody  
(email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 11:35am, from tasting CWT; Chlorine residual - 0 mg/l, collection time 11:30am from ;

Comments

Total Coliform water sample taken tasting room CWT.  
Nitrate water sample taken EP.  
Well and UV Light found in good condition.

END of REPORT

[Submit# 252172] Zugibe Winery (ID 796649) Inspection# 1001896865